

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC POOL AND BATHING PLACE
INSPECTION REPORT



1 of 2

Facility Information

RESULT: Satisfactory

Permit Number: 27-60-00004
Name of Facility: Campers Holiday
Address: 2092 Culbreath Road
City, Zip: Brooksville 34602

Correct By: None
Re-Inspection Date: None

Type: Public Pool > 25000 Gallons
Owner: Trustee Corp. of Campers Holiday
Person In Charge: Ralph King Phone: (352) 796-3707
PIC Email: scunningham0273@yahoo.com
Pool Operator: Ralph King Phone: (352) 251-8233

Inspection Information

Purpose: Routine
Inspection Date: 3/17/2020

Begin Time: 09:10 AM
End Time: 09:55 AM

Additional Information

22. Free Chlorine 5	VOLUME 60120
23. pH 7.4	POOL LOAD 33
24. Chlor. Stabilizer 40	FLOW RATE 168
33. Flowmeter 160	NIGHT SWIM Yes
34. Thermometer 84	FILTER TYPE DEV

Items checked are not in compliance with Chapter 386 or 514, Florida Statutes, or Chapter 64E-9 or 64E-10, Florida Administrative Code. These violations must be corrected by the date indicated to avoid closure, administrative fines, or other legal actions. Florida Building Code (FBC) violations are reported to the local building official, and depending upon risk severity, the Department of Health may close the pool or rescind the operating permit.

Violation Markings

POOL AREA	17. Rules Posted	32. Vacuum Cleaner-FBC
1. Water Clarity/Algae Control	18. Certification	33. Flowmeter
2. Deck/Walkways	SANITARY FACILITIES	34. Thermometer
3. Tile/Pool Finish	19. Supplies 64E-10, FAC	35. Pressure/Vacuum Gauge
4. Depth Markers-FBC	20. Clean 64E-10, FAC	36. Equip. Room
5. Handrail/Ladder-FBC	WATER QUALITY	37. Cross Connection
6. Step Markings-FBC	21. Approved Test Kit	38. Gas Chlorine Eq.-FBC
7. Suction Outlets-514.0315(1)	22. Free Chlor./Brom.	39. Waste Water - FBC
8. Gutter Grates/Skimmer-FBC	23. pH	40. D.E. Separator-FBC
9. Lighting	24. Chlor. Stabilizer	41. Other Equipment
10. No Dive Markings-FBC	25. Spa Requirements-ORP	42. Equip. Change-FBC
11. Diving Board-FBC	EQUIPMENT ROOM	43. Approved Chemicals
12. Pool Cover	26. Wading Pool-Quick Dump	44. Maintenance Log
13. Pool Side Shower-FBC	27. Water Level/Control	45. Inspection Posted
POOL SAFETY	28. Disinfection Feeder/Generator	46. Safety-514.0315(2)
14. Life Hook(s) w/Pole	29. pH Feeder	47. Fences/Gates- FBC
15. Life Ring(s) w/Rope	30. Chem. Container Label-FBC	48. Other
16. Safety Line	31. Filter / Pump	49. Other

NOTE: It is unlawful to modify a public pool or its equipment without prior approval from the local building department and submitting an application to DOH.

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC POOL AND BATHING PLACE
INSPECTION REPORT



2 of 2

General Comments

No violations noted upon inspection.

Email Address(es): scunningham0273@yahoo.com

DOH Web Page For Pools: <http://www.floridahealth.gov/environmental-health/swimming-pools/index.html>

Violations Comments

No Violation Comments Available

Inspection Conducted By: Justin Saukko (51454)
Inspector Contact Number: Work: (352) 540-6800 ex. 82147
Print Client Name: R King
Date: 3/17/2020

Inspector Signature:

Handwritten signature of Justin Saukko.

Client Signature:

Handwritten signature of R King.